

Eyewash Inspection Checklist



Eyewash Inspection Checklist



<p>1. Is the eyewash location marked with a sign?</p>		<p>1. Is the eyewash location marked with a sign?</p>
<p>2. Is the eyewash control device readily accessible and highly visible enough to be easily located?</p>		<p>2. Is the eyewash control device readily accessible and highly visible enough to be easily located?</p>
<p>3. Are the caps in place over the water nozzles in a manner so as to protect them from airborne contaminants?</p>		<p>3. Are the caps in place over the water nozzles in a manner so as to protect them from airborne contaminants?</p>
<p>4. Is the area around the water nozzles clear of obstructions and sharp objects (at least 6 inches from the nozzles in all directions)?</p>		<p>4. Is the area around the water nozzles clear of obstructions and sharp objects (at least 6 inches from the nozzles in all directions)?</p>
<p>5. Do the water nozzle covers automatically come off when the eyewash is activated?</p>		<p>5. Do the water nozzle covers automatically come off when the eyewash is activated?</p>
<p>6. Does water flow from the eyewash within one second of activation of the control device?</p>		<p>6. Does water flow from the eyewash within one second of activation of the control device?</p>
<p>7. To test the eyewash station, flush water until clear water flows continually through eyewash head without any leaks, rust:</p> <ul style="list-style-type: none"> - Is the water clear? - Are the jets working properly? - Is the area around the station clear of obstructions? - Is there a bucket located under the eyewash to collect the run off? - Are they leaking? 		<p>7. To test the eyewash station, flush water until clear water flows continually through eyewash head without any leaks, rust:</p> <ul style="list-style-type: none"> - Is the water clear? - Are the jets working properly? - Is the area around the station clear of obstructions? - Is there a bucket located under the eyewash to collect the run off? - Are they leaking?
<p><i>Please submit a work order to Facilities as soon as possible to have any malfunctions corrected.</i></p>		<p><i>Please submit a work order to Facilities as soon as possible to have any malfunctions corrected.</i></p>

Posted by UNE Environmental Health and Safety
December 2013

Posted by UNE Environmental Health and Safety
December 2013